

**Title:**

The Fire Resistance  
Performance of a  
Non-Loadbearing  
Ceiling Assembly  
Incorporating An  
Access Hatch, Tested  
in Accordance with BS  
EN 1364-2: 2018, With  
Additional Guidance  
From BS EN 1634-  
1:2014 + A1:2018

**Date of Test:**

2<sup>nd</sup> June 2020

**Issue 1:**

19<sup>th</sup> October 2020

**WF Report No.**

422990D/R



**Prepared for:**

Panel Technologies  
Limited

49-61 Jodrell Street  
Nuneaton,  
Warwickshire  
CV11 5EG  
United Kingdom

# Test Specimen

---

## Summary of Tested Specimen

The specimen had approximate overall nominal dimensions of 4000 mm long by 3000 mm wide which comprised of the British Gypsum suspended ceiling configuration referenced G100038. The suspended ceiling assembly referenced British Gypsum G100038 comprised perimeter channel fixed to the supporting construction on all four sides, primary support channels ran transversely across the aperture with secondary support channels spanning the aperture. The framework was clad with three layers of 10 mm thick glassroc multiboard fixed back to the perimeter and secondary support channels. Two structural steel section ran transversely across the aperture and the ceiling assembly was support from these via hanger straps fixed to the primary support channels.

Specimen D was fitted into an aperture 1207 mm long by 907 mm wide. The leaf had overall dimensions of 1195 mm wide x 895 mm long and was pivoted along a singular edge with the opposite edge fitted with a 3 point lock , a layer of mineral wool foil faced was fitted to the leaf to the unexposed face. The hatch opened towards heating conditions and was latched at three points for the duration of the test.

*Detailed drawings of the test specimen(s) and a comprehensive description of the test construction based on a detailed survey of the specimen(s) and information supplied by the sponsor of the test are included in the Test Specimen and Schedule of Components sections of this report.*

## Ceiling Results

|                                                      |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              |                                    |
|------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------|
| <b>General</b>                                       | The ceiling assembly was tested in accordance with BS EN 1364-2: 2018 and the results for the tested assembly.                                                                                                                                                                                                                                                                                                                                                                                                               |                                    |
| <b>Integrity</b>                                     | It is required that the specimen retains its separating function, without either causing ignition of a cotton pad when applied, or permitting the penetration of a gap gauge as specified in BS EN 1634-1: 2014 + A1:2018, or resulting in sustained flaming on the unexposed surface. <b>These requirements were satisfied for the periods shown below:</b>                                                                                                                                                                 |                                    |
| <b>Sustained flaming</b>                             | 4 minutes                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    |                                    |
| <b>Gap gauge</b>                                     | 56 minutes* (6 mm)                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           |                                    |
| <b>Cotton pad</b>                                    | 4 minutes                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    |                                    |
| <b>Insulation (I<sub>2</sub>)</b>                    | The mean temperature rise of the unexposed surface shall not be greater than 140°C and that the maximum temperature rise shall not be greater than 180°C with the exception that the limit for temperature rise for any frame member or transom member adjacent to the leaf/leaves of the doorset or openable window shall be 360°C. Insulation failure also occurs simultaneously with integrity failure as specified in BS EN 1634-1: 2014 + A1:2018. <b>These requirements were satisfied for the period shown below:</b> |                                    |
| <b>Specimen</b>                                      | 1 minutes                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | Exceeded mean temperature criteria |
| *Test was discontinued after a period of 58 minutes. |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              |                                    |

## Signatories


---



Responsible Officer  
**Anthony Green-Morris\***  
Technical Officer



Approved  
**S. Gilfedder\***  
Test Report Co-Ordinator



Head of Department  
**S. Hankey\***  
Business Unit Head – Fire Resistance

\* For and on behalf of **Warringtonfire**.

Report Issued: 19<sup>th</sup> October 2020

This copy has been produced from a .pdf format electronic file that has been provided by **Warringtonfire** to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of **Warringtonfire**. The pdf copy supplied is the sole authentic version of this document. All pdf versions of this report bear authentic signatures of the responsible **Warringtonfire** staff.

## Revision History

|                      |                |
|----------------------|----------------|
| Issue No:            | Re-issue Date: |
| Revised By:          | Approved By:   |
| Reason for Revision: |                |

|                      |                |
|----------------------|----------------|
| Issue No:            | Re-issue Date: |
| Revised By:          | Approved By:   |
| Reason for Revision: |                |

## CONTENTS

## PAGE NO.

|                                       |    |
|---------------------------------------|----|
| TEST SPECIMEN .....                   | 2  |
| CEILING RESULTS .....                 | 3  |
| SIGNATORIES .....                     | 4  |
| REVISION HISTORY .....                | 5  |
| TEST CONDITIONS .....                 | 7  |
| TEST CONSTRUCTION .....               | 8  |
| SCHEDULE OF COMPONENTS .....          | 11 |
| TEST OBSERVATIONS .....               | 14 |
| TEST PHOTOGRAPHS .....                | 15 |
| TEMPERATURE AND DEFLECTION DATA ..... | 16 |
| ON-GOING IMPLICATIONS .....           | 23 |


## Test Conditions

---

|                              |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |
|------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Standard</b>              | BS EN 1364-2: 2018 Fire resistance tests for non-loadbearing elements - Part 2: Ceilings, with additional guidance from BS EN 1634-1:2014 + A1:2018.                                                                                                                                                                                                                                                                                                                                             |
| <b>Sampling</b>              | <b>Warringtonfire</b> was not involved in the sampling or selection of the tested specimen or any of the components. The results obtained during the test only apply to the test samples as provided by the test sponsor.                                                                                                                                                                                                                                                                        |
| <b>Installation</b>          | The specimen was received on the 1 June 2020 and installed into a refractory concrete lined steel restraint frame. The specimen was installed by a representative of the Warringtonfire on the 1 June 2020.                                                                                                                                                                                                                                                                                      |
| <b>Conditioning</b>          | The specimen's storage, construction, and test preparation took place in the test laboratory over a total, combined time of seven days. Throughout this period of time both the temperature and the humidity of the laboratory were measured and recorded as being within a range of from 18°C to 23.5°C and 36.5% to 49% respectively.                                                                                                                                                          |
| <b>Instruction to Test</b>   | <p>The test was conducted on the 2nd June 2020 at the request of Panel Technologies Limited, the test sponsor.</p> <p>Mr. D Blenkinsopp, a representative of the test sponsor witnessed the test.</p>                                                                                                                                                                                                                                                                                            |
| <b>Pre-Test Conditioning</b> | Prior to testing, the hatch was subjected to appropriate mechanical pre-test conditioning in accordance with the requirement of EN 16034:2014, Annex A.                                                                                                                                                                                                                                                                                                                                          |
| <b>Ambient Temperature</b>   | The ambient air temperature in the vicinity of the test construction was 18°C at the start of the test with a maximum variation of +1°C during the test.                                                                                                                                                                                                                                                                                                                                         |
| <b>Furnace</b>               | The furnace was controlled so that its mean temperature complied with the requirements of BS EN 1363-1: 2020 Clause 5.1 using eight plate thermometers, distributed over a plane 100 mm below the surface of the test construction.                                                                                                                                                                                                                                                              |
| <b>Thermocouples</b>         | Thermocouples were provided to monitor the unexposed surface of the specimen. The output of all instrumentation was recorded at no less than one minute intervals. The locations and reference numbers of the various unexposed surface thermocouples are shown in Figure 1.                                                                                                                                                                                                                     |
| <b>Furnace Pressure</b>      | After the first five minutes of testing and for the remainder of the test, the furnace atmospheric pressure was controlled so that it complied with the requirements of BS EN 1363-1: 2020, clause 5.2.1 The calculated pressure differential relative to the laboratory atmosphere 100 mm below the specimen was 20 (+0/-5) Pa between 5 and 10 minutes and 20 (+0/-3) Pa thereafter. Throughout the test there were fluctuations of the pressure conditions due to the nature of the specimen. |

## Test Construction

Figure 1 – General Elevation of Test Construction




- Positions of thermocouples
- × Positions of ceiling support hangers

GENERAL ELEVATION VIEWED FROM UNEXPOSED FACE


Do not scale. All dimensions are in mm

Figure 2 – Details of Panel D – 1200 x 900 mm 12-FR-MD-PF-3WL



Do not scale. All dimensions are in mm

**Figure 3 – Details of Suspended Ceiling**



Do not scale. All dimensions are in mm

# Schedule of Components

(Refer to Figures 1 to 3)  
(All values are nominal unless stated otherwise)  
(All other details are as stated by the sponsor)

| <u>Item</u>                                                                             | <u>Description</u>                                                                                                                                                                                                                                                                                 |
|-----------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>British Gypsum suspended ceiling configuration G100038 (comprising items 1 to 5)</b> |                                                                                                                                                                                                                                                                                                    |
| <b>1. Ceiling perimeter channel</b>                                                     |                                                                                                                                                                                                                                                                                                    |
| Reference                                                                               | : Gypframe MF6                                                                                                                                                                                                                                                                                     |
| Material                                                                                | : Galvanised mild steel formed channel                                                                                                                                                                                                                                                             |
| Thickness                                                                               | : 0.6 mm                                                                                                                                                                                                                                                                                           |
| Overall section size                                                                    | : See Figure 3                                                                                                                                                                                                                                                                                     |
| Fixing method                                                                           | : Fixed to the concrete lining of the specimen restraint frame using 7.5 mm diameter x 40 mm long Multi-Fix masonry screws at 600 mm centres.                                                                                                                                                      |
| <b>2. Ceiling secondary support sections</b>                                            |                                                                                                                                                                                                                                                                                                    |
| Reference                                                                               | : Gypframe MF5                                                                                                                                                                                                                                                                                     |
| Material                                                                                | : Galvanised mild steel section                                                                                                                                                                                                                                                                    |
| Thickness                                                                               | : 0.6 mm                                                                                                                                                                                                                                                                                           |
| Overall section size                                                                    | : See Figure 3                                                                                                                                                                                                                                                                                     |
| Fixing method                                                                           | : Sections were fitted longitudinally screw fixed at 400 mm centres, with each end fitted within the perimeter channel. Sections were also fixed to the primary support channels (see item 3).                                                                                                     |
| <b>3. Ceiling primary support channel</b>                                               |                                                                                                                                                                                                                                                                                                    |
| Reference                                                                               | : Gypframe MF7                                                                                                                                                                                                                                                                                     |
| Material                                                                                | : Galvanised mild steel formed channel                                                                                                                                                                                                                                                             |
| Thickness                                                                               | : 1.2 mm                                                                                                                                                                                                                                                                                           |
| Overall section size                                                                    | : See Figure 3                                                                                                                                                                                                                                                                                     |
| Fixing method                                                                           | : Primary sections fitted laterally across the ceiling on top of the longitudinally fitted secondary sections (item 2) at positions shown on Figure 1. Both sections fixed together at each intersection and perimeter channels using 2 no. 13 mm Gyproc 13 mm wafer head jack-point steel screws. |
| <b>4. Ceiling boards</b>                                                                |                                                                                                                                                                                                                                                                                                    |
| Manufacturer                                                                            | : Saint Gobain                                                                                                                                                                                                                                                                                     |
| Reference                                                                               | : Glasroc F Multiboard                                                                                                                                                                                                                                                                             |
| Material                                                                                | : Glass-reinforced gypsum plasterboard                                                                                                                                                                                                                                                             |
| Thickness                                                                               | : 3 no. layers, each layer 10 mm thick                                                                                                                                                                                                                                                             |
| Supplied board size                                                                     | : 1200 mm x 2400 mm                                                                                                                                                                                                                                                                                |
| Density                                                                                 | : 850 kg/m <sup>3</sup> (stated)                                                                                                                                                                                                                                                                   |
| Fixing method                                                                           | : Gyproc drywall screws at 150 mm centres along the perimeter MF6 channels (item 1) and along the MF5 sections (item 2). 25 mm long screws for first layer boards and 34 mm long screws for the second layer. Board joints of each layer were staggered with respect to each other.                |

| <b><u>Item</u></b>                                                                         | <b><u>Description</u></b>                                                                                                                                                                                                                                                                                              |
|--------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>5. Ceiling support hangers</b>                                                          |                                                                                                                                                                                                                                                                                                                        |
| Type                                                                                       | : Metal fixing band                                                                                                                                                                                                                                                                                                    |
| Reference                                                                                  | : Simpson Strong Tie FB20A                                                                                                                                                                                                                                                                                             |
| Fixing method                                                                              | : Upper end of the band was secured by being strapped around steel support channels which were installed above the ceiling assembly for the purpose of the test.<br>The lower end of the band was screw fixed to the MF7 primary support channel using a single 13 mm wafer head jack-point steel screw. See Figure 3. |
| Quantity                                                                                   | : For positions of the hangers, see Figure 1.                                                                                                                                                                                                                                                                          |
| <b>Access panel assembly – 1200 x 900 mm 12-FR-MD-PF-3WL (consisting of items 6 to 11)</b> |                                                                                                                                                                                                                                                                                                                        |
| <b>6. Mounting frame</b>                                                                   |                                                                                                                                                                                                                                                                                                                        |
| Material                                                                                   | : Zinc mild steel                                                                                                                                                                                                                                                                                                      |
| Thickness                                                                                  | : 1.2 mm steel                                                                                                                                                                                                                                                                                                         |
| Opening size                                                                               | : 1207 mm x 907 mm                                                                                                                                                                                                                                                                                                     |
| Overall Frame size                                                                         | : 1250 mm x 950 mm                                                                                                                                                                                                                                                                                                     |
| Fixing method                                                                              | : Screw fixed in place using 3.5 x 50 mm bright zinc plated (BZP) countersunk pozi bugle head cross recess self drilling drywall screws at 300 mm centres                                                                                                                                                              |
| <b>7. Door panel</b>                                                                       |                                                                                                                                                                                                                                                                                                                        |
| Material                                                                                   | : Zinc mild steel                                                                                                                                                                                                                                                                                                      |
| Thickness                                                                                  | : 0.9 mm steel                                                                                                                                                                                                                                                                                                         |
| Overall size                                                                               | : 1195 mm x 895 mm                                                                                                                                                                                                                                                                                                     |
| Fixing method to frame                                                                     | : Fixed with full length piano hinge. Panel was locked with using 3-point lock.                                                                                                                                                                                                                                        |
| <b>8. Door infill</b>                                                                      |                                                                                                                                                                                                                                                                                                                        |
| Manufacturer                                                                               | : Rockwool                                                                                                                                                                                                                                                                                                             |
| Reference                                                                                  | : Ductslab                                                                                                                                                                                                                                                                                                             |
| Material                                                                                   | : Stone wool                                                                                                                                                                                                                                                                                                           |
| Thickness                                                                                  | : 40 mm                                                                                                                                                                                                                                                                                                                |
| Density                                                                                    | : 45 kg/m <sup>3</sup> (stated)                                                                                                                                                                                                                                                                                        |
| Fixing method to frame                                                                     | : Slid under door leaf to return leaf                                                                                                                                                                                                                                                                                  |
| <b>9. 3 – Point lock</b>                                                                   |                                                                                                                                                                                                                                                                                                                        |
| Manufacturer                                                                               | : C.R.A International                                                                                                                                                                                                                                                                                                  |
| Type                                                                                       | : 3 - point lock assembly                                                                                                                                                                                                                                                                                              |
| Material                                                                                   |                                                                                                                                                                                                                                                                                                                        |
| i. Latch casing                                                                            | : BZP Mild steel                                                                                                                                                                                                                                                                                                       |
| ii. Locking bar                                                                            | : 304 Grade 8mm Diameter Round Bar                                                                                                                                                                                                                                                                                     |
| iii. Latch                                                                                 | : BZP Mild Steel                                                                                                                                                                                                                                                                                                       |
| Overall Size                                                                               |                                                                                                                                                                                                                                                                                                                        |
| i. Latch Casing                                                                            | : 16mm x 162mm                                                                                                                                                                                                                                                                                                         |
| ii. Locking Bar                                                                            | : 8mm Diameter                                                                                                                                                                                                                                                                                                         |
| iii. Latch                                                                                 | : 18mm x 4mm                                                                                                                                                                                                                                                                                                           |
| Operation                                                                                  | : Engaged                                                                                                                                                                                                                                                                                                              |
| <b>10. Draught Seal</b>                                                                    |                                                                                                                                                                                                                                                                                                                        |
| Manufacturer                                                                               | : CB Frost                                                                                                                                                                                                                                                                                                             |
| Reference                                                                                  | : CF6 PU 8X4                                                                                                                                                                                                                                                                                                           |
| Material                                                                                   | : Self Adhesive Light Grey PU Foam Strip                                                                                                                                                                                                                                                                               |
| Section size                                                                               | : 8 mm x 3 mm                                                                                                                                                                                                                                                                                                          |

Fixing method : Self-adhered into the frame rebate.

**Item**

**11. Piano Hinge**

**Description**

|                                |                                                                            |
|--------------------------------|----------------------------------------------------------------------------|
| Manufacturer                   | : Cooke Brothers                                                           |
| Reference                      | : 543441101.                                                               |
| Material                       | : Mild Steel                                                               |
| Overall sizes                  | : 3" width open, 1.5mm thick material, 6mm Ø hinge pin with 1" long joints |
| Fixing method                  |                                                                            |
| i. to door frame               | : 4 no. M6 steel screws per blade                                          |
| ii. to door leaf               | : M6 Nuts and Washers                                                      |
| Details of Fixings             |                                                                            |
| i. Type                        | : Screws complete with suitable nuts and washers                           |
| ii. Material                   | : Steel                                                                    |
| iii. Size                      | : 25 mm long x 6 mm diameter                                               |
| iv. Number Off Per Hinge Blade | : 4 No.                                                                    |
| Details of Bedding Material    | : None                                                                     |

## Test Observations

---


| Time |      | All observations are from the unexposed face unless noted otherwise.                                                                            |
|------|------|-------------------------------------------------------------------------------------------------------------------------------------------------|
| mins | secs |                                                                                                                                                 |
| 00   | 00   | <b>The test commences.</b>                                                                                                                      |
| 02   | 48   | Steam/smoke from the perimeter of Hatch D.                                                                                                      |
| 04   | 11   | Dark grey discolouration around the perimeter of Hatch D.                                                                                       |
| 21   | 42   | The leaf of hatch D can be seen to be bowing towards heating conditions.                                                                        |
| 42   | 06   | Sustained flaming from longitudinal edge of hatch D. Sustained flaming integrity failure is deemed to have occurred.                            |
| 58   | 30   | <b>Part of the suspended ceiling has detached from the main structure and the test has become unsafe to continue. The test is discontinued.</b> |

## Test Photographs

The unexposed  
face of the  
specimen prior to  
testing



The unexposed  
face of Hatch D  
showing  
sustained flaming  
at 42 minutes



## Temperature and Deflection Data

Mean Furnace Temperature, Together With The Temperature/Time Relationship Specified In The Standard

| Time<br>Mins | Specified<br>Furnace<br>Temperature<br>Deg. C | Actual<br>Furnace<br>Temperature<br>Deg. C |
|--------------|-----------------------------------------------|--------------------------------------------|
| 0            | 20                                            | 102                                        |
| 2            | 445                                           | 440                                        |
| 4            | 544                                           | 567                                        |
| 6            | 603                                           | 597                                        |
| 8            | 646                                           | 660                                        |
| 10           | 678                                           | 682                                        |
| 12           | 706                                           | 697                                        |
| 14           | 728                                           | 729                                        |
| 16           | 748                                           | 753                                        |
| 18           | 766                                           | 768                                        |
| 20           | 781                                           | 784                                        |
| 22           | 796                                           | 795                                        |
| 24           | 809                                           | 808                                        |
| 26           | 820                                           | 818                                        |
| 28           | 832                                           | 827                                        |
| 30           | 842                                           | 836                                        |
| 32           | 852                                           | 848                                        |
| 34           | 860                                           | 864                                        |
| 36           | 869                                           | 867                                        |
| 38           | 877                                           | 883                                        |
| 40           | 885                                           | 894                                        |
| 42           | 892                                           | 902                                        |
| 44           | 899                                           | 905                                        |
| 46           | 906                                           | 906                                        |
| 48           | 912                                           | 913                                        |
| 50           | 918                                           | 918                                        |
| 52           | 924                                           | 922                                        |
| 54           | 930                                           | 933                                        |
| 56           | 935                                           | 935                                        |
| 58           | 940                                           | 943                                        |

**Individual And Mean Temperatures Recorded On The Unexposed Surface Of Specimen D Panel**  
**Leaf**

| Time<br>Mins | T/C<br>Number<br>231<br>Deg. C | T/C<br>Number<br>232<br>Deg. C | T/C<br>Number<br>233<br>Deg. C | T/C<br>Number<br>234<br>Deg. C | T/C<br>Number<br>235<br>Deg. C | Mean<br>Temp<br>Deg. C |
|--------------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|------------------------|
| 0            | 25                             | 25                             | 25                             | 30                             | 26                             | 26                     |
| 2            | 25                             | 25                             | 25                             | 31                             | 26                             | 26                     |
| 4            | 26                             | 26                             | 26                             | 32                             | 27                             | 27                     |
| 6            | 27                             | 29                             | 29                             | 43                             | 28                             | 31                     |
| 8            | 34                             | 36                             | 38                             | 46                             | 35                             | 38                     |
| 10           | 41                             | 42                             | 43                             | 49                             | 41                             | 43                     |
| 12           | 45                             | 49                             | 47                             | 52                             | 46                             | 48                     |
| 14           | 48                             | 63                             | 55                             | 58                             | 55                             | 56                     |
| 16           | 56                             | 75                             | 67                             | 68                             | 67                             | 67                     |
| 18           | 68                             | 100                            | 83                             | 80                             | 75                             | 81                     |
| 20           | 76                             | 110                            | 106                            | 107                            | 105                            | 101                    |
| 22           | 97                             | 128                            | 115                            | 119                            | 114                            | 115                    |
| 24           | 117                            | 155                            | 131                            | 140                            | 131                            | 135                    |
| 26           | 140                            | 177                            | 152                            | 167                            | 157                            | 159                    |
| 28           | 163                            | 195                            | 167                            | 179                            | 175                            | 176                    |
| 30           | 180                            | 210                            | 178                            | 191                            | 187                            | 189                    |
| 32           | 193                            | 223                            | 187                            | 209                            | 197                            | 202                    |
| 34           | 201                            | 235                            | 195                            | 205                            | 203                            | 208                    |
| 36           | 211                            | 245                            | 201                            | 215                            | 211                            | 217                    |
| 38           | 219                            | 259                            | 211                            | 224                            | 219                            | 226                    |
| 40           | 231                            | 273                            | 218                            | 229                            | 229                            | 236                    |
| 42           | 242                            | 282                            | 226                            | 241                            | 239                            | 246                    |
| 44           | 249                            | 288                            | 235                            | 249                            | 246                            | 253                    |
| 46           | 257                            | 292                            | 240                            | 254                            | 253                            | 259                    |
| 48           | 260                            | 295                            | 241                            | 257                            | 257                            | 262                    |
| 50           | 262                            | 300                            | 246                            | 260                            | 262                            | 266                    |
| 52           | 264                            | 302                            | 247                            | 264                            | 263                            | 268                    |
| 54           | 263                            | 305                            | 250                            | 264                            | 264                            | 269                    |
| 56           | 268                            | 308                            | 252                            | 268                            | 266                            | 272                    |
| 58           | 270                            | 311                            | 255                            | 269                            | 272                            | 275                    |

**Individual Temperatures Recorded On The Unexposed Surface Of Specimen D Panel Frame**


| Time<br>Mins | T/C<br>Number<br>258<br>Deg. C | T/C<br>Number<br>259<br>Deg. C | T/C<br>Number<br>260<br>Deg. C | T/C<br>Number<br>261<br>Deg. C | T/C<br>Number<br>262<br>Deg. C | T/C<br>Number<br>263<br>Deg. C |
|--------------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|
| 0            | 29                             | 27                             | 29                             | 24                             | 26                             | 27                             |
| 2            | 52                             | 43                             | 52                             | *                              | 36                             | 34                             |
| 4            | 127                            | 98                             | 133                            | *                              | 65                             | 87                             |
| 6            | 271                            | 146                            | 219                            | *                              | 91                             | 150                            |
| 8            | 338                            | 175                            | 250                            | *                              | 114                            | 218                            |
| 10           | 377                            | 194                            | 265                            | *                              | 136                            | 267                            |
| 11           | 388                            | 205                            | 271                            | *                              | 149                            | 280                            |
| 12           | 391                            | 214                            | 275                            | *                              | 163                            | 288                            |
| 14           | 399                            | 233                            | 287                            | *                              | 188                            | 304                            |
| 16           | 399                            | 251                            | 306                            | *                              | 214                            | 322                            |
| 18           | 397                            | 269                            | 345                            | *                              | 237                            | 336                            |
| 20           | 397                            | 286                            | 400                            | *                              | 256                            | 346                            |
| 22           | 401                            | 299                            | 439                            | *                              | 274                            | 361                            |
| 24           | 403                            | 311                            | 456                            | *                              | 291                            | 383                            |
| 26           | 403                            | 320                            | 465                            | *                              | 304                            | 408                            |
| 28           | 401                            | 330                            | 472                            | *                              | 315                            | 420                            |
| 30           | 400                            | 338                            | 479                            | *                              | 325                            | 430                            |
| 32           | 398                            | 350                            | 488                            | *                              | 334                            | 438                            |
| 34           | 393                            | 359                            | 495                            | *                              | 344                            | 442                            |
| 36           | 402                            | 363                            | 512                            | *                              | 350                            | 446                            |
| 38           | 410                            | 369                            | 520                            | *                              | 355                            | 451                            |
| 40           | 412                            | 377                            | 521                            | *                              | 361                            | 458                            |
| 42           | 409                            | 383                            | 519                            | *                              | 368                            | 474                            |
| 44           | 412                            | 383                            | 522                            | *                              | 371                            | 489                            |
| 46           | 414                            | 382                            | 526                            | *                              | 375                            | 498                            |
| 48           | 414                            | 383                            | 529                            | *                              | 380                            | 503                            |
| 50           | 416                            | 382                            | 529                            | *                              | 385                            | 502                            |
| 52           | 408                            | 378                            | 504                            | *                              | 388                            | 498                            |
| 54           | 416                            | 379                            | 533                            | *                              | 391                            | 496                            |
| 56           | 415                            | 377                            | 536                            | *                              | 395                            | 495                            |
| 58           | 407                            | 375                            | 522                            | *                              | 398                            | 492                            |

\*Thermocouple Malfunction


**Individual Temperatures Recorded On The Unexposed Surface Of Specimen D 100 mm Away  
From The Edges**

| Time<br>Mins | T/C<br>Number<br>242<br>Deg. C | T/C<br>Number<br>245<br>Deg. C | T/C<br>Number<br>246<br>Deg. C | T/C<br>Number<br>247<br>Deg. C | T/C<br>Number<br>264<br>Deg. C | T/C<br>Number<br>265<br>Deg. C |
|--------------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|
| 0            | 24                             | 25                             | 25                             | 25                             | 26                             | 25                             |
| 2            | 26                             | 26                             | 25                             | 25                             | 27                             | 25                             |
| 4            | 37                             | 37                             | 29                             | 27                             | 26                             | 29                             |
| 6            | 38                             | 34                             | 95                             | 30                             | 34                             | 45                             |
| 8            | 43                             | 45                             | 94                             | 37                             | 46                             | 51                             |
| 10           | 47                             | 50                             | 84                             | 43                             | 47                             | 53                             |
| 12           | 53                             | 52                             | 74                             | 48                             | 49                             | 58                             |
| 14           | 64                             | 58                             | 89                             | 59                             | 59                             | 79                             |
| 16           | 77                             | 67                             | 107                            | 71                             | 80                             | 99                             |
| 18           | 108                            | 74                             | 123                            | 93                             | 105                            | 110                            |
| 20           | 123                            | 92                             | 145                            | 116                            | 120                            | 115                            |
| 22           | 147                            | 115                            | 165                            | 133                            | 141                            | 121                            |
| 24           | 168                            | 134                            | 182                            | 156                            | 166                            | 126                            |
| 26           | 184                            | 159                            | 196                            | 172                            | 184                            | 129                            |
| 28           | 197                            | 176                            | 206                            | 184                            | 198                            | 138                            |
| 30           | 209                            | 190                            | 218                            | 195                            | 208                            | 138                            |
| 32           | 218                            | 199                            | 228                            | 207                            | 215                            | 142                            |
| 34           | 226                            | 205                            | 237                            | 217                            | 223                            | 145                            |
| 36           | 236                            | 217                            | 249                            | 230                            | 230                            | 149                            |
| 38           | 244                            | 227                            | 264                            | 246                            | 243                            | 154                            |
| 40           | 256                            | 238                            | 280                            | 260                            | 250                            | 160                            |
| 42           | 267                            | 248                            | 293                            | 269                            | 258                            | 172                            |
| 44           | 275                            | 258                            | 302                            | 277                            | 267                            | 181                            |
| 46           | 281                            | 264                            | 309                            | 282                            | 269                            | 185                            |
| 48           | 284                            | 266                            | 311                            | 285                            | 267                            | 189                            |
| 50           | 290                            | 271                            | 319                            | 292                            | 277                            | 186                            |
| 52           | 292                            | 268                            | 317                            | 290                            | 276                            | 186                            |
| 54           | 294                            | 272                            | 322                            | 297                            | 280                            | 184                            |
| 56           | 296                            | 277                            | 327                            | 298                            | 283                            | 181                            |
| 58           | 302                            | 282                            | 328                            | 302                            | 285                            | 181                            |


**Graph Showing Mean Furnace Temperature, Together With The Temperature/Time Relationship Specified In The Standard**



**Graph Showing Mean Temperature Recorded On The Unexposed Surface Of Specimen D Panel Leaf**



**Graph Showing Recorded Furnace Pressure 100 mm Below The Specimen**



## On-going Implications

---

### Limitations

This report details the method of construction, the test conditions and the results obtained when the specific elements of construction described herein were tested following the procedure outlined in BS EN 1363-1: 2020, and where appropriate BS EN 1363-2: 1999. Any significant deviation with respect to size, constructional details, loads, stresses, edge or end conditions other than those allowed under the field of direct application in the relevant test method is not covered by this report. Annex A of BS EN 1363-1: 2020, provides guidance information on the application of fire resistance tests and the interpretation of test data.

Because of the nature of fire resistance testing and the consequent difficulty in quantifying the uncertainty of measurement of fire resistance, it is not possible to provide a stated degree of accuracy of the result.

### EGOLF

Certain aspects of some fire test specifications are open to different interpretations. EGOLF have identified a number of such areas and have agreed Resolutions which define common agreement of interpretations between fire test laboratories which are members of the Groups. Where such Resolutions are applicable to this test they have been followed